



कार्यालय अधिशासी अभियन्ता (मु०)  
जलकल विभाग, नगर निगम प्रयागराज  
पत्र सं० 156..... मु०ज०क०वि०  
दिनांक 23/02/26

## JAL KAL VIBHAG NAGAR NIGAM PRAYAGRAJ CHEMICAL ANALYSIS LABORATORY

Report No. DW/01/LAB2026-02/09

Date: 20.02.2026

### DRINKING WATER ANALYSIS REPORT

1	Name & Address	VIDYA BHARTI PUBLIC SCHOOL, VILL-IMLIGAON, NEVADA DIST. KAUSHAMBI, U.P
2	Sample Collected by	By Party
3	Nature of Sample	DRINKING WATER
4	Date of Sample Collection	17.02.2026
5	Date of Sample Receiving	17.02.2026
6	Date of Analysis Completed	20.02.2026

S.N.	PHYSICAL PARAMETERS	UNITS	OBSERVED VALUE	STANDARDS (IS 10500-2012)	
				Desirable Limit	Permissible Limit
1.	Colour, units.	-	Colourless	-	-
2.	Odour	Agreeable	Odourless	Agreeable	
3.	Temperature	°C	22.1	-	-
4.	Turbidity	NTU	0.2	5	10
5.	Conductivity at 25°C	µmho/cm	292.0	-	-
<b>CHEMICAL PARAMETERS</b>					
6.	pH	-	7.2	6.5 to 8.5	No Relaxation
7.	Suspended Solids	mg/L	NIL	-	-
8.	Dissolved Solids	mg/L	139.0	500	2000
9.	Total Solids	mg/L	139.0	-	-
10.	Total Alkalinity (as CaCO <sub>3</sub> )	mg/L	100.0	200	600
11.	Total Hardness (as CaCO <sub>3</sub> )	mg/L	140.0	200	600
12.	Chlorides (as Cl)	mg/L	22.0	250	1000
13.	Fluoride (as f) mg/l	mg/L	0.1	1.0	1.5
14.	Nitrate (as NO <sub>3</sub> )	mg/L	1.88	45.0	100.0
15.	Iron (Fe)	mg/L	<BDL	0.3	1.0
<b>BACTERIOLOGICAL PARAMETERS</b>					
16.	Total Coliform	MPN/100ml	Absent	Absent	-
17.	E. Coli	MPN/100ml	Absent	Absent	-

Validity- three months only

Analyst

JE(HQ)

अधिशासी अभियन्ता (मु०)  
जलकल विभाग  
नगर निगम-प्रयागराज

- Note:**
1. The above results are related only to the test performed on the sample.
  2. This report is not to be reproduce wholly or in part and can not be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.
  3. Sample will be destroyed in the after fifteen days from the date of reporting.

# Annexure-C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.636

Dated: 07/03/2026

It is certified that an inspection team headed by Praveen Kutti -Executive Engineer (Name of Officers with designation) from Jal Nigam ,Prayagraj (PHED/Municipality)

Inspected the VIDYA BHARTI PUBLIC SCHOOL,VILLAGE- IMLIGAON, NEVADA , KAUSHAMBI, UTTAR PRADESH, 212218 (Name & Address of the school) on 28/02/2026

(date of inspection) and on the basis of Water Test Report (Attached) bearing no

DW/01/LAB2026-02/09 dated 20/02/2026 of JAL KAL VIBHAG NAGAR NIGAM PRAYAGRAJ

CHEMICAL ANALYSIS LABORATORY (PHED Lab) certified that the

VIDYA BHARTI PUBLIC SCHOOL,VILLAGE IMLIGAON, NEVADA , KAUSHAMBI,

UTTAR PRADESH, 212218 ( Name of school) has safe drinking

water facilities for the students and members of staff of the institution. School also maintains

the hygienic sanitation condition in the school building & the campus as per norms prescribed by

the Central/ State/ U.T. Govt.

This certificate is valid from to 07/03/2026 to 06/03/2029( 03 Years).

Signature with Seal: .....

Name

: Praveen Kutti

Designation

: Executive Engineer

Name & Address of the Office/Department:

Jal Nigam Prayagraj

Executive Engi  
Jal Nigam  
Prayagraj

To

THE MANAGER

VIDYA BHARTI PUBLIC SCHOOL

VILLAGE- IMLIGAON, NEVADA ,

KAUSHAMBI, UTTAR PRADESH

(Name & Address of the Institution)

1|Page

